

CERTIFICATE

DEKRA

Issued to:

Applicant:

RENEW PHOTOVOLTAICS PRIVATE LIMITED
PLOT NO-DTA-02-40 TO 45, DOMESTIC TARIFF
AREA PHASE-II, MAHINDRA WORLD CITY
TAHSILSANGANER
302037 Jaipur, Na, Rajasthan, India

Licensee:

RENEW PHOTOVOLTAICS PRIVATE LIMITED
PLOT NO-DTA-02-40 TO 45, DOMESTIC TARIFF
AREA PHASE-II, MAHINDRA WORLD CITY
TAHSILSANGANER
302037 Jaipur, Na, Rajasthan, India

Product : Photovoltaic (PV) Module(s)
Trade name(s) : ReNew
Type(s)/model(s) : PV module with mono c-Si cells

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- an evaluation according to the standard(s) IEC 61701:2020 and EN IEC 61701:2020
- a periodic surveillance
- a DEKRA certification agreement with the number 6067326

DEKRA hereby grants the right to use the DEKRA Seal certification mark with the following content:

Category : Photovoltaic
Keyword : Salt Mist Resistance
Keyword : Periodic Factory Inspection

The DEKRA Seal certification mark may be applied to the product or documentation as specified in this certificate for the duration and under the conditions of the DEKRA Seal certification agreement.

This certificate is issued on 14 November 2025 and expires at the latest on 28 June 2029.

Certificate number: 31-143170 REV.2

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



Cliff Lin
Certification Manager

© Integral publication of this certificate is allowed



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Photovoltaic (PV) Module(s)
Trade name(s)	: ReNew
Type(s)/model(s)	: RPS2MH54BDXXX, RPS2MH72BDXXX and RPS3MH66BDXXX
Test condition	: Test methods 6

Product data – type RPS2MH54BDXXX

Design	: PV module with mono c-Si cells (double-glass module)
Maximum system voltage	: 1500V
Description	: xxx= 430-450, in steps of 5, 108 cells

Product data – type RPS2MH72BDXXX

Design	: PV module with mono c-Si cells (double-glass module)
Maximum system voltage	: 1500V
Description	: xxx= 570-610, in steps of 5, 144 cells xxx= 540-560, in steps of 5, 144 cells

Product data – type RPS3MH66BDXXX

Design	: PV module with mono c-Si cells (double-glass module)
Maximum system voltage	: 1500V
Description	: xxx=600-645, in steps of 5, 132 cells

TESTS**Test requirements**

IEC 61701:2020
EN IEC 61701:2020

Test result

The test results are documented in DEKRA test file 624100300.

Additional information

This certificate replaces certificate No. 31-143170 REV.1 which we hereby declare invalid.

The list of components is laid down in test report 6241003B.50.

Conclusion

The examination has confirmed that all requirements were met.

Factory locations

RENEW PHOTOVOLTAICS PRIVATE LIMITED
PLOT NO-DTA-02-40 TO 45, DOMESTIC TARIFF AREA PHASE-II, MAHINDRA WORLD CITY
TAHSILSANGANER
302037 Jaipur, Na, Rajasthan, India

RENEW PHOTOVOLTAICS PRIVATE LIMITED
PLOT NO. 232, TP-2/A DHOLERA SPECIAL INVESTMENT REGION, DHOLERA
382455 Ahmedabad, Gujarat, India

Trade name(s): ReNew stands for

ReNew**Unique Identifier**

The DEKRA Seal has been updated with a modern look. Both the new and old designs of the seal are shown on this certificate, and you may use either version. We strongly encourage you to use the new version for a clearer and more contemporary representation of your certification.

New DEKRA Seal certification mark design:



Old DEKRA Seal certification mark design:

